



PENTESTING ICS 101

Arnaud SOULLIE
Alexandrine TORRENTS

WAVESTONE

Who are we?



Interests

- / **Windows Active Directory:** Can a Windows AD be secured ? JSSI 2014 (French, sorry)
- / **SCADA** (BHEU14, HIP15, BruCon, BSLV15, DC24)
- / **Wine tasting** / **Motorbike riding**
(we're not going to talk about it today)
- / **Sorry for the French accent**



Who are we?



Alexandrine
Torrents


Security auditor

Interests

- / **SCADA** (BruCON)
- / **Penetration testing**
- / Cinema

LAB PREREQUISITE

What's in the lab VM?



KALI LINUX



ADDITIONAL
TOOLS

/ ModbusPal
/ Mbtget
/ Plcscan
/ Snap7
/ ...



SCRIPTS

/ PCAP samples
/ Scripts
skeletons
/ ...

The VM is available on USB stick

AGENDA

/ **01** Introduction to ICS

/ **02** What's wrong with ICS security?

/ **03** Programming PLCs

/ **04** Pentesting PLCs

/ **05** Capture the flag !

/ **06** Securing ICS

Hands-on !

Hands-on !

Hands-on !

 1h

 1h30

 1h30



ICS Introduction

Where do we find Industrial Control Systems ?




Manufacturing plants
Food

Power plants
Building automation
systems (AC/HVAC/..)
Water treatment
Pharmaceutical
manufacturing
Chemical plants

But also...swimming
pools, building
heating system,
dams, etc.

What is an Industrial Control System (ICS)?



Corporate IS handle data

≠


ICS handle interfaces data with physical world (cyber-physical systems)

What about IoT / smart stuff ?

Fit the definition of « cyber-physical » systems

- / Cardio-meter for your smartphone
- / « Smart » electrical plugs

By the way, « smart » clearly isn't the right word



<http://weputachipinit.tumblr.com/>



➔ Not in the scope of this training

Evolution of ICS

- / Started with electrical relays ➔ hard wired automation, no update possible
- / Then moved to programmable electronics
- / Then to IP-network enabled devices
- / Now and future is more and more COTS

ICS evolution timeline


- / From 1700s : Industrial revolution
- / 1900s : use of relays to control remote systems
- / 1950s : use of punch paper tape to control machines
- / 1960s : use of distributed control to control a plant
- / 1969 : First PLCs
- / 1973 : Modbus invented
- / 1986 : PLCs controled by PCs
- / 1992 : TCP/IP for PLCs
- / 2003 : web servers for PLCs
- / ~2010s : Brace yourselves, AD is coming !
- / Then what for the 10 next years ??

Future of ICS (well at least, current trends)

Now and future is more and more COTS

Active Directory domains

Soft-PLCs : CodeSYS under Windows computers



CODESYS Control RTE: Real-time SoftPLC under Windows


CODESYS Control RTE: Real-time SoftPLC for PC-based industrial controllers (PLCs) under Windows, programmable with the IEC 61131-3 Development System CODESYS

Overview Howtoget Download

CODESYS Control RTE

- Executable under Windows XP/Embedded/7/8 (32/64 Bit) with single or multi core CPUs
- Has its own real time kernel: deterministic behavior with jitter values in the μs region without additional hardware components or operating system extensions
- Supports several interfaces to inputs and outputs: Discrete I/O cards or standard fieldbus cards
- Supports the configuration of the standard fieldbuses directly in the IEC 61131-3 Development System, no external tools required
- Adaptable with a special toolkit (CODESYS RTE Runtime System Toolkit): API driver interface for customized I/O drivers and C functions and SoftPLC-specific configurations
- Supports remanent data: hard disk, flash card, battery buffered SRAM card

Future of ICS (well at least, current trends)



This is what happens when you start using too much IT in OT

A bit of vocabulary

ICS (Industrial Control System)

=

IACS (Industrial Automation and Control Systems)

≈

SCADA (Supervisory Control And Data Acquisition)

≈

DCS (Distributed Control System)

Nowadays, people tend to say “SCADA” for anything related to ICS

SCADA vs DCS

In theory ...

- / SCADA : event / data acquisition driven
- / Used across several sites (even at the country scale)
- / Can work even when offline
- / Low response time

- / DCS : process driven
- / Limited to local process monitoring
- / DCS works as standalone system
- / Dedicated products by the vendors for specific industries / process

In reality ...

In the real world, you'll find some PLCs even when DCS is used

Today, SCADA manufacturer tend to have DCS functionality, while DCS systems response time is lowering to be comparable to traditional SCADA response time

SCADA vs DCS

Siemens vision (1/3)

Characteristic	PLC	DCS
Market Introduction	1960s	1975
Replacement of . . .	Electromechanical Relays	Pneumatic & Single-Loop Controllers
Products Manufactured . . .	"Things"	"Stuff"
Classic Application	Automotive	Refining
Type of Control	Discrete	Regulatory
Redundancy	"Warm" Backup	"Hot" Backup
Engineering Mindset	"Programming"	"Configuration"
Operator Interaction	Exception Basis	Man in the Loop
Operator Interface	Simple Graphics	Sophisticated Graphics
Size/Footprint	Compact	Large
Up-front cost	\$\$	\$\$\$\$
System	"Open"	"Closed" (Proprietary)

Table 1 Classic Stereotypes of PLC vs. DCS

From « DCS or PLC? Seven Questions to Help You Select the Best Solution »
http://w3.siemens.com/mcms/process-control-systems/SiteCollectionDocuments/efiles/pcs7/support/marktstudien/PLC_or_DCS.pdf

SCADA vs DCS

Siemens vision (2/3)

PLC	<input type="checkbox"/> Manufacturing or assembly of specific items (aka "Things")	<input type="checkbox"/> Involves the combination and/or transformation of raw materials (aka "Stuff")	DCS
	<input type="checkbox"/> Product is visible as it moves through the process	<input type="checkbox"/> Often impossible to visually see the product as it moves through the process	
	<input type="checkbox"/> High-speed logic control (such as motors)	<input type="checkbox"/> Regulatory/Analog (loop) control	
	<input type="checkbox"/> Simple Batch control	<input type="checkbox"/> Complex Batch Control	
PLC	<input type="checkbox"/> Value of the individual component being manufactured is relatively low	<input type="checkbox"/> The value of a "batch" can be very high (either in raw material cost or market value)	DCS
	<input type="checkbox"/> Downtime mainly results in lost production	<input type="checkbox"/> Downtime not only results in lost production, but can result in dangerous conditions	
	<input type="checkbox"/> Downtime does not typically damage the process equipment	<input type="checkbox"/> Downtime can result in process equipment damage (product hardens, etc.)	
	<input type="checkbox"/> Return to steady state production after an outage is short and relatively straightforward	<input type="checkbox"/> Return to steady state production after an unplanned outage can be long, expensive, and difficult	
PLC	<input type="checkbox"/> Typically, the heart of the system is the controller	<input type="checkbox"/> Typically, the heart of the system is the HMI	DCS
PLC	<input type="checkbox"/> The operator's primary role is to handle exceptions	<input type="checkbox"/> The operator's interaction is typically required to keep the process in its target performance range	DCS
	<input type="checkbox"/> Status information (On/Off, Run/Stop) is critical information for the operator	<input type="checkbox"/> Faceplates and analog trends are critical to "see" what is happening to the process	
	<input type="checkbox"/> Exception-based alarming is key information for the operator	<input type="checkbox"/> Alarm management is key to safe operation of the process and for responding effectively during plant upset conditions	
	<input type="checkbox"/> Manufacturing might be able to run "lights-out"	<input type="checkbox"/> Failure of the HMI could force the shutdown of the process	

SCADA vs DCS

Siemens vision (3/3)

PLC	<input type="checkbox"/> Fast logic scan (approx. 10ms) is required to perform motor or motion control	<input type="checkbox"/> Control loops require deterministic scan execution at a speed of 100 to 500 ms	DCS
	<input type="checkbox"/> Redundancy may not be cost justified	<input type="checkbox"/> System redundancy is often required	
	<input type="checkbox"/> System can be taken offline to make configuration changes	<input type="checkbox"/> Online configuration changes often required	
	<input type="checkbox"/> Analog Control: Simple PID only	<input type="checkbox"/> Analog Control: Simple to advanced PID control up to Advanced Process Control	
	<input type="checkbox"/> Diagnostics to tell you when something is broken	<input type="checkbox"/> Asset Management alerts you to what might break before it does	
PLC	<input type="checkbox"/> High level programming languages are available for creating custom logic	<input type="checkbox"/> Custom logic created from existing function blocks	DCS
	<input type="checkbox"/> Customized routines usually required	<input type="checkbox"/> Many algorithms (i.e. PID) are complex and do not vary among applications	
	<input type="checkbox"/> Standard libraries considered nice features	<input type="checkbox"/> Standard application libraries are expected (function blocks and faceplates)	
	<input type="checkbox"/> Provisions must be available to integrate functions/ products into an integrated architecture	<input type="checkbox"/> Entire system is expected to function as a complete solution	
PLC	<input type="checkbox"/> Program/configure individual components, integrate later (bottom-up)	<input type="checkbox"/> Up-front design of complete system before implementation begins (top-down)	DCS
	<input type="checkbox"/> Desire customizable platforms to build upon	<input type="checkbox"/> Looking for significant "out-of-the-box" functionality	
	<input type="checkbox"/> System designed to be flexible	<input type="checkbox"/> System designed to make it "easy" to engineer process applications	
	<input type="checkbox"/> Solution is generic in nature, to be applied on a wide variety of applications	<input type="checkbox"/> Use of pre-defined, pre-tested functions saves time	
	<input type="checkbox"/> Use ladder logic to configure application	<input type="checkbox"/> Use function block diagram to configuration application	

ICS COMPONENTS


- ➔ **Sensors and actuators:** allow interaction with the physical world (pressure sensor, valves, motors, ...)
- ➔ **Local HMI:** Human-Machine Interface, permits the supervision and control of a subprocess
- ➔ **PLC:** Programmable Logic Controller : manages the sensors and actuators
- ➔ **Supervision screen:** remote supervision of the industrial process
- ➔ **Data historian:** Records all the data from the production and Scada networks
- ➔ **RTU:** Remote Terminal Unit (standalone PLC)
- ➔ **IED:** Intelligent Electronic Device (smart sensor)



 A data historian screen displaying a table of recorded data. The table has multiple columns and rows, showing various numerical values and timestamps.

TIME	TEMPERATURE	PRESSURE	FLOW	LEVEL	STATUS
2023-10-27 10:00:00	120.5	15.2	10.1	85.3	OK
2023-10-27 10:01:00	121.0	15.5	10.2	85.5	OK
2023-10-27 10:02:00	121.5	15.8	10.3	85.7	OK
2023-10-27 10:03:00	122.0	16.0	10.4	85.9	OK
2023-10-27 10:04:00	122.5	16.2	10.5	86.1	OK
2023-10-27 10:05:00	123.0	16.5	10.6	86.3	OK
2023-10-27 10:06:00	123.5	16.8	10.7	86.5	OK
2023-10-27 10:07:00	124.0	17.0	10.8	86.7	OK
2023-10-27 10:08:00	124.5	17.2	10.9	86.9	OK
2023-10-27 10:09:00	125.0	17.5	11.0	87.1	OK
2023-10-27 10:10:00	125.5	17.8	11.1	87.3	OK
2023-10-27 10:11:00	126.0	18.0	11.2	87.5	OK
2023-10-27 10:12:00	126.5	18.2	11.3	87.7	OK
2023-10-27 10:13:00	127.0	18.5	11.4	87.9	OK
2023-10-27 10:14:00	127.5	18.8	11.5	88.1	OK
2023-10-27 10:15:00	128.0	19.0	11.6	88.3	OK
2023-10-27 10:16:00	128.5	19.2	11.7	88.5	OK
2023-10-27 10:17:00	129.0	19.5	11.8	88.7	OK
2023-10-27 10:18:00	129.5	19.8	11.9	88.9	OK
2023-10-27 10:19:00	130.0	20.0	12.0	89.1	OK
2023-10-27 10:20:00	130.5	20.2	12.1	89.3	OK
2023-10-27 10:21:00	131.0	20.5	12.2	89.5	OK
2023-10-27 10:22:00	131.5	20.8	12.3	89.7	OK
2023-10-27 10:23:00	132.0	21.0	12.4	89.9	OK
2023-10-27 10:24:00	132.5	21.2	12.5	90.1	OK
2023-10-27 10:25:00	133.0	21.5	12.6	90.3	OK
2023-10-27 10:26:00	133.5	21.8	12.7	90.5	OK
2023-10-27 10:27:00	134.0	22.0	12.8	90.7	OK
2023-10-27 10:28:00	134.5	22.2	12.9	90.9	OK
2023-10-27 10:29:00	135.0	22.5	13.0	91.1	OK
2023-10-27 10:30:00	135.5	22.8	13.1	91.3	OK
2023-10-27 10:31:00	136.0	23.0	13.2	91.5	OK
2023-10-27 10:32:00	136.5	23.2	13.3	91.7	OK
2023-10-27 10:33:00	137.0	23.5	13.4	91.9	OK
2023-10-27 10:34:00	137.5	23.8	13.5	92.1	OK
2023-10-27 10:35:00	138.0	24.0	13.6	92.3	OK
2023-10-27 10:36:00	138.5	24.2	13.7	92.5	OK
2023-10-27 10:37:00	139.0	24.5	13.8	92.7	OK
2023-10-27 10:38:00	139.5	24.8	13.9	92.9	OK
2023-10-27 10:39:00	140.0	25.0	14.0	93.1	OK
2023-10-27 10:40:00	140.5	25.2	14.1	93.3	OK
2023-10-27 10:41:00	141.0	25.5	14.2	93.5	OK
2023-10-27 10:42:00	141.5	25.8	14.3	93.7	OK
2023-10-27 10:43:00	142.0	26.0	14.4	93.9	OK
2023-10-27 10:44:00	142.5	26.2	14.5	94.1	OK
2023-10-27 10:45:00	143.0	26.5	14.6	94.3	OK
2023-10-27 10:46:00	143.5	26.8	14.7	94.5	OK
2023-10-27 10:47:00	144.0	27.0	14.8	94.7	OK
2023-10-27 10:48:00	144.5	27.2	14.9	94.9	OK
2023-10-27 10:49:00	145.0	27.5	15.0	95.1	OK
2023-10-27 10:50:00	145.5	27.8	15.1	95.3	OK
2023-10-27 10:51:00	146.0	28.0	15.2	95.5	OK
2023-10-27 10:52:00	146.5	28.2	15.3	95.7	OK
2023-10-27 10:53:00	147.0	28.5	15.4	95.9	OK
2023-10-27 10:54:00	147.5	28.8	15.5	96.1	OK
2023-10-27 10:55:00	148.0	29.0	15.6	96.3	OK
2023-10-27 10:56:00	148.5	29.2	15.7	96.5	OK
2023-10-27 10:57:00	149.0	29.5	15.8	96.7	OK
2023-10-27 10:58:00	149.5	29.8	15.9	96.9	OK
2023-10-27 10:59:00	150.0	30.0	16.0	97.1	OK
2023-10-27 11:00:00	150.5	30.2	16.1	97.3	OK
2023-10-27 11:01:00	151.0	30.5	16.2	97.5	OK
2023-10-27 11:02:00	151.5	30.8	16.3	97.7	OK
2023-10-27 11:03:00	152.0	31.0	16.4	97.9	OK
2023-10-27 11:04:00	152.5	31.2	16.5	98.1	OK
2023-10-27 11:05:00	153.0	31.5	16.6	98.3	OK
2023-10-27 11:06:00	153.5	31.8	16.7	98.5	OK
2023-10-27 11:07:00	154.0	32.0	16.8	98.7	OK
2023-10-27 11:08:00	154.5	32.2	16.9	98.9	OK
2023-10-27 11:09:00	155.0	32.5	17.0	99.1	OK
2023-10-27 11:10:00	155.5	32.8	17.1	99.3	OK
2023-10-27 11:11:00	156.0	33.0	17.2	99.5	OK
2023-10-27 11:12:00	156.5	33.2	17.3	99.7	OK
2023-10-27 11:13:00	157.0	33.5	17.4	99.9	OK
2023-10-27 11:14:00	157.5	33.8	17.5	100.1	OK
2023-10-27 11:15:00	158.0	34.0	17.6	100.3	OK
2023-10-27 11:16:00	158.5	34.2	17.7	100.5	OK
2023-10-27 11:17:00	159.0	34.5	17.8	100.7	OK
2023-10-27 11:18:00	159.5	34.8	17.9	100.9	OK
2023-10-27 11:19:00	160.0	35.0	18.0	101.1	OK
2023-10-27 11:20:00	160.5	35.2	18.1	101.3	OK
2023-10-27 11:21:00	161.0	35.5	18.2	101.5	OK
2023-10-27 11:22:00	161.5	35.8	18.3	101.7	OK
2023-10-27 11:23:00	162.0	36.0	18.4	101.9	OK
2023-10-27 11:24:00	162.5	36.2	18.5	102.1	OK
2023-10-27 11:25:00	163.0	36.5	18.6	102.3	OK
2023-10-27 11:26:00	163.5	36.8	18.7	102.5	OK
2023-10-27 11:27:00	164.0	37.0	18.8	102.7	OK
2023-10-27 11:28:00	164.5	37.2	18.9	102.9	OK
2023-10-27 11:29:00	165.0	37.5	19.0	103.1	OK
2023-10-27 11:30:00	165.5	37.8	19.1	103.3	OK
2023-10-27 11:31:00	166.0	38.0	19.2	103.5	OK
2023-10-27 11:32:00	166.5	38.2	19.3	103.7	OK
2023-10-27 11:33:00	167.0	38.5	19.4	103.9	OK
2023-10-27 11:34:00	167.5	38.8	19.5	104.1	OK
2023-10-27 11:35:00	168.0	39.0	19.6	104.3	OK
2023-10-27 11:36:00	168.5	39.2	19.7	104.5	OK
2023-10-27 11:37:00	169.0	39.5	19.8	104.7	OK
2023-10-27 11:38:00	169.5	39.8	19.9	104.9	OK
2023-10-27 11:39:00	170.0	40.0	20.0	105.1	OK
2023-10-27 11:40:00	170.5	40.2	20.1	105.3	OK
2023-10-27 11:41:00	171.0	40.5	20.2	105.5	OK
2023-10-27 11:42:00	171.5	40.8	20.3	105.7	OK
2023-10-27 11:43:00	172.0	41.0	20.4	105.9	OK
2023-10-27 11:44:00	172.5	41.2	20.5	106.1	OK
2023-10-27 11:45:00	173.0	41.5	20.6	106.3	OK
2023-10-27 11:46:00	173.5	41.8	20.7	106.5	OK
2023-10-27 11:47:00	174.0	42.0	20.8	106.7	OK
2023-10-27 11:48:00	174.5	42.2	20.9	106.9	OK
2023-10-27 11:49:00	175.0	42.5	21.0	107.1	OK
2023-10-27 11:50:00	175.5	42.8	21.1	107.3	OK
2023-10-27 11:51:00	176.0	43.0	21.2	107.5	OK
2023-10-27 11:52:00	176.5	43.2	21.3	107.7	OK
2023-10-27 11:53:00	177.0	43.5	21.4	107.9	OK
2023-10-27 11:54:00	177.5	43.8	21.5	108.1	OK
2023-10-27 11:55:00	178.0	44.0	21.6	108.3	OK
2023-10-27 11:56:00	178.5	44.2	21.7	108.5	OK
2023-10-27 11:57:00	179.0	44.5	21.8	108.7	OK
2023-10-27 11:58:00	179.5	44.8	21.9	108.9	OK
2023-10-27 11:59:00	180.0	45.0	22.0	109.1	OK
2023-10-27 12:00:00	180.5	45.2	22.1	109.3	OK

CIM (Computer Integrated Manufacturing) pyramid



Industrial protocols

At the beginning, specific protocols on specific **physical layer** (RS232, RS285, 4-20 current loop)

Some protocols were **adapted to TCP/IP**, like Modbus, and other were developed to allow interoperability.

Currently, the most used seem to be :

- / HART / Wireless HART
- / Profibus
- / Modbus
- / Profinet / S7
- / DNP3
- / For the field protocols (used by the PLCs, and some « intelligent » sensors/actuators)
- / OPC for data exchanged with the corporate network / Windows-based systems


ICS vendors



IT vs OT

- / The essential criteria for ICS security is **availability**, not confidentiality
- / ICS were designed to be isolated, but today need to **communicate with the outside world**
- / The use of COTS and standard protocols is relatively new
- / Lifetime of components span **over decades**
- / **No security awareness**

IT vs OT



OT

Availability : My system is working correctly

Integrity : My system is working as expected

OT cares more about **safety**

Applied regularly on standards systems	Security patches	Only recently provided by vendors. Applied once a year tops
Deployed on all Windows machines, centrally managed	Antivirus	Slowly starting to show up. Some vendors used to / stil forbid AV usage (lack of support if AV is installed) Not managed
Centralized, dedicated teams, standard operations and procedures	System Administration	Lack of local skills, heterogeneous environments, lots of different tools to use, vendor support is mandatory
Nominative accounts	IAM	Generic, shared accounts, no password policy
Service interruptions are OK, especially outside business hours	Availability	Real-time operations, downtime is unacceptable or very costly
Standard, TCP/IP protocols that include authentication and encryption	Protocols	Lot of vendor-specific protocol no security built in
No people endangered	Impact	Possible impact of people, environnement, industrial gear

SCADA SECURITY AWARENESS TIMELINE (SIMPLIFIED)


AIN'T NOBODY GOT TIME

<2011


Who cares ?

FO DAT

SCADA SECURITY AWARENESS TIMELINE (SIMPLIFIED)



SCADA SECURITY AWARENESS TIMELINE (SIMPLIFIED)



ICS security awareness is growing

At the government level



Regulations

In industrial companies



Policies

**For the general
audience**



Fear

Vendors Cyber-Security offer

Most ICS vendors have now understood the client's worries about security and offer different kinds of dedicated products and/or services

That DOES NOT mean that vendors' staff has the required knowledge and training about ICS security



Cyber Security Services

Schneider Electric addresses an organization's compliance and cyber security challenges from analysis through to implementation and management. We start by providing expert consulting with a track record of global success to assess the current compliance situation. We then define an overall Cyber Security plan and remediation strategy encompassing processes, procedures, people, products, networks and applications.

The Cyber Security portfolio ensures regulatory compliance for:

- Power Generation: NERC CIP
- Nuclear: 10 CFR 73.54, NEI 08-09, Regulatory Guide 5.71
- Chemical and Water: CFATS
- Petroleum, Oil and Gas: Internal or industry regulations

Our solution is unique because it provides Cyber Security compliance for a company's critical infrastructure and integrates seamlessly between manufacturing operations and corporate information Technology networks.

Key aspects of Managed Security Service


- Security incident response and resolution guidance
- Onsite re-assessment of security posture, personnel training and process enhancement
- Continuous monitoring of security and system status
- Proactive threat notification based on real-time global intelligence
- Implementation of security updates to address changing threat landscape





What's wrong with ICS security?

What is wrong with current ICS security?



Organization & awareness



No true ICS cybersecurity sector

- / ICS security does not have the same level of maturity as IT in general
- / You will often face situation where nobody is in charge of ICS security
- / Sometimes, there is even nobody in charge of IT (computers, switches)
- / Someone is in charge of ICS safety, but not security
- / ICS are often still out of the CISO perimeter

No representative on the field

- / Very few awareness on cyber risks
- / No formation on information systems

No budgetary line for ICS cyber-securing

Misconceptions

SAFETY != SECURITY

Our ICS are not connected

Proprietary protocols are safer

I have an Antivirus, I am safe

\$BIG_VENDOR products are certainly secure

The safety systems will prevent anything bad from happening

Network segmentation

Business needs

Send information to the corporate network

/ Production supervision

/ Bills issuing

/ Etc.

Allow remote maintenance

➔ More and more interconnections with ICS

Security needs

Unidentified!

Filtering often wrongly done, with non-dedicated equipment
A lot of “dangerous” flows accessible from the corporate network

Network segmentation

- / Mostly a fail
- / Nothing is air-gapped, ever (well, almost)
- / « It is segmented because my laptop can't connect to both networks at the same time »
- / Often, poorly configured ACLs on routers
- / Wide access to the ICS from the
 - › Port 80 allowed to everyone
 - › Spoiler alert : port 80 allows to do plenty of nasty things
- / How good is your network segmentation if you directly copy files from the office network to the ICS network ?

A close-up photograph of a computer keyboard. The focus is on a red key in the lower center that has the words "Nuclear Strike" printed on it in a light gray, sans-serif font. Surrounding this key are various other keys: to the left is a gray key with double and single quotes; above it are white keys for F11, F12 (with a speaker icon), delete, and a key with a plus/equals sign; to the right are white keys for fn, home, page up, delete (with a small 'x' icon), end, and page down; below the red key is a large gray shift key. A semi-transparent purple horizontal band is overlaid across the middle of the image, containing white text.

Finding scada systems on
the internet

EXPOSE ONLINE DEVICES.

WEBCAMS. ROUTERS.
POWER PLANTS. IPHONES. WIND TURBINES.
REFRIGERATORS. VOIP PHONES.

[TAKE A TOUR](#)[FREE SIGN UP](#)

- / Shodan is a search engine dedicated to find devices exposed to the Internet
- / It regularly scans the whole Internet IPV4 range (~4,3 billions IPs)
- / Results are partially free (you have to pay to export the results)

What can you find?


- / All kinds of connected devices
 - › PLCs
 - › Webcams
 - › Smart-things (fridge, TV, ...)
- / Things you can't even imagine...
- / Example ICS report:
<https://www.shodan.io/report/l7VjfVKc>

Alternatives?

- / Scan the Internet yourself
(Zmap, Massscan)
- / Other online
services/surveys

FUNNY things you can find on teh interwebs

It's not just webcams.



This is a
crematorium.
On the internet.

Internet exposure

<http://www.scadaexposure.com>

Vendor	Product	WORLD	IT	CH	Total
ABB	Generic	8	0	0	0
	RTU500	7	0	0	0
ACKP	Generic	267	22	5	27
Adcon Telemetry	A850 Telemetry Gateway	25	0	0	0
	Generic	105	0	0	0
	addUPI-OPC Server	261	1	0	1
Allen-Bradley	Generic	3665	74	15	89
Beck IPC	IPC@CHIP	4172	520	120	640
BroadWeb	Generic	10	0	0	0
Cimetrics	Eplus - B/IP to B/WS Gateway Firewall	7	0	0	0
Clorius Controls	Generic	1	0	0	0
Codesys	WebVisu	30	0	2	2
Delta Controls	entelITOUCH	109	0	0	0
Tridium	Generic	19530	235	32	267
Wago	Generic	115	6	31	37
Wind River	Generic	10817	875	66	941
		126533	3296	867	4163

More than 100 000 exposed equipment!!!

Vulnerability management : a hard topic

Impossibility to patch some components as it requires a stop and a restart

- / ICS help industries make money. Most of the time, by producing something. The more « uptime » the ICS has, the more money you make. That is why a lot of ICS run 24/7
- / Each production stop costs money, hence the difficulty to regularly apply security patches.

Difficulty to implement a watch on vulnerabilities and security patches

- / Non exhaustive or lack of cartography on installations
- / Obsolete components which support is no longer assured

No test environment to evaluate impact on production or safety of the security patches

As ICS hardware is much more costly than VMs, sometimes security patches must be applied to production directly.

Lack of security mechanism in equipment and protocols

Technologies axed on availability and longevity that do not take into account security concerns

Frequent vulnerabilities on ICS protocols

- / Information exchanged in clear-text
- / Replay possibilities
- / Lack of authentication

Frequent vulnerabilities on PLCs

- / Weak authentication
- / Default password
- / « *Hardcoded* » password
(Schneider took 2363jd to provide an update correcting a hardcoded password, and still not on all PLCs...)

ICS-CERT Metrics	2010 Totals	2011 Totals	2012 Totals
ICS Incident Reported — tickets	39	204	138
ICS Incident Response Onsite Deployments	8	7	6
ICS Related Vulnerability Report — tickets	41	141	147
ICS-CERT Information Products	138	283	343

Lack of third party management

Suppliers / editors are still too often in a strong position

- / Remote maintenance often a requirement (non secured...)
- / Unguaranteed products in case of security patch installation or even antivirus

They often provide equipment in their default / non hardened configuration

The introduction of malicious components is eased by the important volume of employees' in and out and the multiplication of suppliers



Lack of security supervision



Supervision is at the heart of SCADA systems, it is even their primary purpose

However, security supervision is almost non-existent

Equipment do not have event logging or incident notification protocols

Because of interconnection requirements, a security operation center cannot be easily put together

HEATER ON



ICS Protocols

INDICATOR

CHARGER ON



FLOAT



HI-RATE



ALARM

LED TEST



CHARGER
VOLTAGE LOW



CHARGER FAIL



CHARGER
VOLTAGE HIGH



ALARM
RESET



AC FAIL




+VE EARTH
FAULT



-VE EARTH
FAULT



CHARGER OUTPUT




Security in protocols

ICS devices often use proprietary protocols, and there are also several standards

That is why on a given plant/factory ICS, you are likely to find several protocols in use

We will cover the most used ones



Modbus protocol




- / Serial communication protocol invented in 1979 by Schneider Electric
 - / Developed for industrial application
 - / Royalty-free
 - / Now one of the standards for industrial communications
-

How it works:

- / Master / Slave protocol
- / Master must regularly poll the slaves to get information
- / Modbus addresses are 8 bits long, so only 247 slaves per master
- / There is no object description: a request returns a value, without any context or unit

Security anyone?

- / Clear-text
- / No authentication



Modbus protocol



- / Modbus was originally made for serial communications
 - / However it is now often used over TCP (port 502)
-

Modbus TCP/IP frame

- / Transaction identifier set by the sender
- / Protocol identifier set to 0 (default Modbus value)

Transaction identifier	Protocol identifier	Length field	Slave address	Funtion code	Data
					Variable structure depending on the function
2 bytes	2 bytes	2 bytes	1 byte	1 byte	N bytes

Modbus protocol



Modbus functions

- / The most common Modbus functions allow to read and write data from/to a PLC
- / Other functions, such as file read and diagnostics functions also exist
- / Undocumented Modbus function codes can also be used to perform specific actions

COMMONLY USED MODBUS function codes

Function name	Function code
Read coils	1
Write single coil	5
Read holding registers	3
Write single register	6
Write multiple registers	16
Read/Write multiple registers	23

Modbus protocol



Function type			Function name	Function code
Data Access	Bit access	Physical Discrete Inputs	Read Discrete Inputs	2
		Internal Bits or Physical Coils	Read Coils	1
			Write Single Coil	5
			Write Multiple Coils	15
	16-bit access	Physical Input Registers	Read Input Registers	4
		Internal Registers or Physical Output Registers	Read Holding Registers	3
			Write Single Register	6
			Write Multiple Registers	16
			Read/Write Multiple Registers	23
			Mask Write Register	22
			Read FIFO Queue	24
			File Record Access	Read File Record
	Write File Record	21		
Diagnostics			Read Exception Status	7
			Diagnostic	8
			Get Com Event Counter	11
			Get Com Event Log	12
			Report Slave ID	17
			Read Device Identification	43
Other			Encapsulated Interface Transport	43

S7 protocol



- / Proprietary protocol by Siemens
- / No security
- / New version of the protocol available starting with version 4 and up of the PLC firmware : provides mutual authentication and communication encryption
- / Security features analyzed by Quarkslab, see the talk from SSTIC https://www.sstic.org/2015/presentation/analyse_de_scurite_de_technologies_proprietaires_scada

	Couche OSI	Protocole
7	Couche application	S7 communication
6	Couche présentation	S7 communication
5	Couche session	S7 communication
4	Couche transport	ISO-on-TCP
3	Couche réseau	IP
2	Couche liaison	Ethernet
1	Couche physique	Ethernet

- / 3 steps to establish a connection with a Siemens PLC:
 - > Connect to the PLC via TCP on **port 102**
 - > Connect to ISO layer (COTP Connect Request)
 - > Connect to the S7comm layer
- / S7comm protocol rely on the following protocols:
 - > **COTP** : Connection-Oriented Transport Protocol
 - > **TPKT** : "ISO transport services on top of the TCP"
 - > **TCP** : TPKT use TCP as transport protocol

DNP3 protocol



- / Standard protocol, developed by GE in the 90's
- / Slave/Slave: Information can be share at the initiative of any device
- / Layer 2 protocol (just top of physical layer), ported to TCP/IP
- / Integrity is verified using CRC
- / Data reporting communication: only send the data that has changed (simplified), or at the initiative of the PLC/RTU
- / Used for smart grids in the US
- / Secure DNP3 introduced in 2007
 - › Works on serial and TCP versions
 - › Challenge/response to exchange a session key (using PSK)
 - › Can be done at startup, every XX minutes, or only for sensitive actions (write requests for example)
 - › There is also an aggressive mode, which can be exploited to perform replay attacks
 - › Possible to use secure DNP3 over TLS

Profibus protocol



- / Standard protocol
- / Used for communication with field devices (sensors/actuators)
- / Uses 4-20mA current loop

OPC protocol



- / Standard protocol
- / Used to exchange data between ICS and Windows devices
- / Works on TCP/IP
- / Several variants:
 - › OPC-DA : Data access, used to gather data from the process control
 - › OPC A&E : Alarm & Events
 - › OPC HDA : Historical Data Access
 - › OPC DX : Data Exchange, allow to exchange data between OPC servers
 - › OPC Security
 - › OPC XML-DA
 - › OPC UA : Unified Architecture, aimed at replacing the others while using a more modern Service Oriented Architecture.
- / Provides authentication and encryption, probably the future of ICS protocols

#Foreverdays

#foreverdays is a term coined by @reverseics
Very important concept when talking about ICS
The highest vulnerabilities are not patched.

So it is really worth considering the effort of patch management
of ICS equipment when you know




Programming PLCs

process


What is a PLC?

- / Real-time digital computer used for automation
- / Replaces electrical relays
- / Lots of analogue or digital inputs & outputs
- / Rugged devices (immune to vibration, electrical noise, temperature, dust, ...)

What's inside?



Siemens S7-1200



A few pics of PLCs




PLC programming

“Ladder Logic” was the first programming language for PLC, as it mimics the real-life circuits

IEC 61131-3 defines 5 programming languages for PLCs

- / **LD:** Ladder Diagram
- / **FBD:** Function Block Diagram
- / **ST:** Structured Text
- / **IL:** Instruction List
- / **SFC:** Sequential Function Chart

Ladder diagram example



Structured text example

```
(* simple state machine *)
TxtState := STATES[StateMachine];


CASE StateMachine OF
  1: ClosingValve();
ELSE
  ;; BadCase();
END_CASE;
```

Instruction list example

LD	Speed	
	GT	1000
	JMPCN	VOLTS_OK
	LD	Volts
VOLTS_OK	LD	1
	ST	%Q75

Programming with SoMachine

- / SoMachine is the software provided by Schneider Electric to program the entry-level PLCs.
- / PLCs used in big plants are usually programmed using Unity Pro, for which there is no free demo version.
- / Fortunately, the way this software work is very much the same




PLC programming

- > Create a project
- > Define the hardware setup
- > Create variables
- > Define the program
- > Test
- > Debug
- > Push to PLC
- > START


PLC programming

- / Production line
- / Flipped-over bottles must be put in the tray




PLC programming

- / The main motor must only start if the oil pump is running
- / Motor must stop is X3 is pressed



PLC programming

- / Another production line
- / Display indicates when 10 packages
- / A button allows resetting the display





PENTESTING PLCs



Lab Session #1: Analyzing a Modbus communication with Wireshark

- / Analyze a modbus communication with Wireshark
- / Wireshark owns by default a modbus dissector

4	0.001595	127.0.0.1	127.0.0.1	Modbus/TCP
5	0.001638	127.0.0.1	127.0.0.1	TCP
6	0.015000	127.0.0.1	127.0.0.1	Modbus/TCP
7	0.015047	127.0.0.1	127.0.0.1	TCP
8	0.015226	127.0.0.1	127.0.0.1	TCP
9	0.019268	127.0.0.1	127.0.0.1	TCP
10	0.019310	127.0.0.1	127.0.0.1	TCP
11	15.592238	127.0.0.1	127.0.0.1	TCP
12	15.592255	127.0.0.1	127.0.0.1	TCP

Transmission Control Protocol, Src Port: 33834 (33834), Dst Port: asa-appt-	
Modbus/TCP	
Transaction Identifier: 28737	
Protocol Identifier: 0	
Length: 6	
Unit Identifier: 1	
Modbus	
Function Code: Read Holding Registers (3)	
Reference Number: 0	
Word Count: 16	

- / Launch Wireshark
- / Open « modbus1.pcap »
- / Try to understand what's going on
 - > Reading request
 - > Writing request
 - > PLC's answer
- / What's the value of register #123 at the end?

Lab session #2: ModbusPal

/ Modbuspal is a modbus simulator

```
$ > cd /root/toolz/modbus
```

```
$ > java -jar ModbusPal.jar
```


/ Add a modbus slave

/ Set some register values

/ Query it with:

- > MBTGET Perl script
- > Metasploit module

/ Analyze traffic with Wireshark



Lab session #2: ModbusPal + MBTGET

/ Mbtget is a perl script to perform Modbus/tcp queries

```
$ > cd root/toolz/modbus/mbtget/scripts
```

```
$ > ./mbtget -h
```

/ Read requests

> Coils (1 bit)

```
$ > ./mbtget -r1 -a 0 -n 8 127.0.0.1
```

> Words (8 bits)

```
$ > ./mbtget -r3 -a 0 -n 8 127.0.0.1
```


/ Write requests

> Coils (1 bit)

```
$ > ./mbtget -w5 #{VALUE} -a 0 127.0.0.1
```

> Words (8 bits)

```
$ > ./mbtget -w6 #{VALUE} -a 0 127.0.0.1
```



Lab session #2: ModbusPal + Metasploit

- / A simple Modbus client
- / Can perform read and write operations on coils and registers

/ Launch msfconsole


```
$ > msfconsole
```

```
msf > use auxiliary/scanner/scada/modbusclient
```

```
msf auxiliary(modbusclient) > info
```

/ Play!

```
msf auxiliary(modbusclient) > set ACTION
```



```
msf auxiliary(modbusclient) > set RHOST 127.0.0.1
RHOST => 127.0.0.1
msf auxiliary(modbusclient) > set DATA_ADDRESS 0
DATA_ADDRESS => 0
msf auxiliary(modbusclient) > run

[*] Sending READ REGISTER...
[+] Register value at address 0 : 123
[*] Auxiliary module execution completed
msf auxiliary(modbusclient) > 
```

```
msf auxiliary(modbusclient) > set ACTION WRITE_REGISTER
ACTION => WRITE_REGISTER
msf auxiliary(modbusclient) > set DATA 321
DATA => 321
msf auxiliary(modbusclient) > run

[*] Sending WRITE REGISTER...
[+] Value 321 successfully written at registry address 0
[*] Auxiliary module execution completed
msf auxiliary(modbusclient) > set ACTION READ_REGISTER
ACTION => READ_REGISTER
msf auxiliary(modbusclient) > run

[*] Sending READ REGISTER...
[+] Register value at address 0 : 321
[*] Auxiliary module execution completed
msf auxiliary(modbusclient) > 
```

Lab session #3 : S7 using Snap7

- / Snap7 is an open-source library implementing Siemens S7 protocol
- / It is pretty complete for “old” PLCs, but all functionalities do not work with more recent PLCs (S7-1200, S7-1500)

- / Launch the demo server


```
$ > cd toolz/siemens/Snap7demos
$ > ./serverdemo
```

- / Query it using the demo client

```
$ > ./clientdemo
```

- / You can also use the scripts that rely on the Snap7 python wrappers

```
$ > cd toolz/siemens/
$ > python S7get.py
$ > python S7getDB.py
```



WARNING

The following show features stunts performed either by professionals or under the supervision of professionals.

Attacking
PLCs

Never do this
on **LIVE production** systems

performed on this show.




Reconnaissance

- / Objective : Identify all exposed services on a device or a range of devices
- / Often the first step in a pentest

- / We will use two tools
 - › **Nmap**: The world's finest port scanner
 - › **PLCSCAN**: A reconnaissance tool dedicated to PLCs

- / Network information
 - › Wifi SSID: "ICS_101" (pass : "yoloscada")
 - › DHCP to obtain an address (192.168.0.100 and up)
 - › Targets are between 192.168.0.0 and 192.168.0.75

Reconnaissance (Nmap)



- / The de-facto tool for port scanning but can be really dangerous on ICS
- / Two stories from NIST SP800-82
 - › A ping sweep broke for over 50 000\$ in product at a semi-conductor factory
 - › The blocking of gas distribution for several hours after a pentester went slightly off-perimeter during an assessment for a gas company
- / Nmap useful setup for ICS scanning
 - › Reduce scanning speed! Use « --scan-delay=1 » to scan one port at a time
 - › Perform a TCP scan instead of a SYN scan
 - › Do not perform UDP scan
 - › Do not use fingerprinting functions, and manually select scripts (do not use "-sC")

```
$ nmap -sT --scan-delay=1 192.168.0.0/24
```

```
$ nmap -p- -sT --scan-delay=1 <IP_address>
```

Reconnaissance (PLCSCAN)

Siemens PLC

```
127.0.0.1:102 577000 / 577000 00100 00100 00100
```

```
Module
Basic Hardwa
Basic Firmwa
Unknown (129
Name of the
Name of the
Plant identi
Copyright
Serial numbe
Module type
```

/ <https://code.google.com/p/plcscan/>
(<http://scadastrangelove.org/>)

by

SCADAStrangeLove

/ Scans for ports **102** (Siemens) and **502** (Modbus) and tries to pull information about the PLC (modules, firmware version,...)

Modbus device

```
127.0.0.1:502 |
```

```
Unit ID: 0
Response e
Device inf
Unit ID: 255
Response e
Device: La
```

/ Not exhaustive since not all PLCs use Modbus or are Siemens

/ What if I told you there was another way... SNMP ?

```
$ python plcscan.py <IP_address>
```


Capture the flag

Your mission, should you choose to accept it, is to stop the train and capture the flag with the robot arm.

Hacking
ICS ?
It's




No crazy « hanging from the ceiling without sweating » stuff required !



Attacking standard services

- / Most PLCs have standard interfaces, such as **HTTP** and **FTP**
- / Lets' say security was not the first thing in mind when introducing these features ...



- / On Schneider M340
 - › FTP credentials are hardcoded
sysdiag / factorycast@schneider
 - › Allows you to retrieve the password file for the web UI

Lab session #4 : Attacking PLCs

/ Unauthenticated actions on PLCs

- › Schneider "STOP/RUN"

```
msf > use auxiliary/admin/scada/modicon_command
```

- › Schneider "Logic download/upload"

```
msf > use auxiliary/admin/scada/modicon_stux_transfer
```

MSF's module is not working properly on large programs.

I made some ****unfinished**** modifications on my Github :

https://github.com/arnaudsoullie/metasploit-framework/blob/master/modules/auxiliary/admin/scada/modicon_stux_transfer.rb

Also included in your VM as « modicon_stux_transfer_ASO »



Securing ICS


Securing ICS

- / ICS security standards
 - › Comparison
 - › ANSSI
 - › ISA99
 - › 62443
- / System hardening
- / Network segmentation
 - › Theory
 - › Necessary evil : data exchange
 - › Technical solutions : FW, DMZ, Data diodes
- / Security monitoring
 - › Why?
 - › How?
 - › Integration with process supervision?

ICS security standards

There are quite a few !


Let's use a document published by the CLUSIF, a French information security association.



<https://www.clusif.asso.fr/fr/production/ouvrages/pdf/CLUSIF-2014-Cyber-Security-of-Industrial-Control-Systems.pdf>

ISA 99 / IEC 62443

ISA 99 is the old name, the document was initially created by the ISA (International Society for Automation)




http://en.wikipedia.org/wiki/Cyber_security_standards#/media/File:ISA-62443_Standard_Series_2012.png

ISA 99 / ISO 62443

A few concepts :

- / **Security lifecycle:** security must be integrated during each phase of a product development, use and end of life
- / **Zones and conduits:** Instead of applying the same security level and security measures to all parts of the ICS, the ICS is segmented in zones, which have a homogeneous security level, and « conduits » are defined to exchange information between zones.
- / **Security levels:** Define security levels in the same way as SIL (Safety Integrity Levels) [Note that there is no correlation whatsoever between security levels and safety levels]
- / **Target Security Levels**
- / **Achieved Security Levels**
- / **Capability Security Levels**

Figure 3: Network zones and conduits



NIST SP800-82

NIST = National Institute for Standards and Technology

Much more technical than the IEC 62443





Figure 2-2. SCADA System General Layout

Old-school icon set ☺

French specific standards : The ANSSI

Really well done, ~~but only in French at the moment~~ now in English!

<http://www.ssi.gouv.fr/administration/guide/la-cybersecurite-des-systemes-industriels/>



RIPE

Created by Langner Security

RIPE : Robust ICS Planning and Evaluation.

Rejects the idea of risk management (I am exaggerating a bit), and focuses on security capabilities

Based on concepts from quality management, with 3 attributes:

- › Verifiability
- › Completeness
- › Accuracy

Composed of 8 domains :

- › System population Characteristics
- › Network architecture
- › Component Interaction
- › Workforce Roles and Responsibilities
- › Workforce Skills and Competence Development
- › Procedural Guidance
- › Deliberate Design and Configuration Change
- › System acquisition

System hardening

We won't cover all the possible ways to harden a server configuration.

There are numerous quality resources on the topic, here are a few :

- › DISA : <http://iase.disa.mil/stigs/Pages/index.aspx>
- › CIS : <https://benchmarks.cisecurity.org/downloads/>
- › ...

However, here are the biggest topics

- › Patching process
- › Services
- › Attack surface
- › User accounts & permissions
- › File permissions
- › Network configuration
- › Remote administration

System hardening: whitelisting

Since configuration and software do not change much in ICS, it is possible to go one step further in hardening

- / You can use **whitelisting technologies** to prevent any unauthorized program from being executed
- / **AppLocker** from Microsoft allows you to do that, as well as some 3rd party tools, most of the time by AV companies (McAfee, Symantec, ...)
- / It is also possible to perform regular, **automated configuration review** to detect unauthorized changes
- / Not to be forgotten: in case of vulnerability exploitation or if you have admin access, this could be bypassed

Network segmentation: why & how?

First question: why do we need to have network segmentation?

- / Impacts of a compromise are higher on an ICS
- / We cannot afford to have attackers from the corporate network pivot to the ICS

Second question: how to segregate the networks?

- / Real question is : how to segregate while allowing some communications
- / Let's take a look at NIST SP800-82

Network segmentation: Dual home

1st solution : Dual-homed workstations or servers – two network cards

- / One of the corporate network
- / One on the ICS network

Network segmentation: Firewall

A firewall filters flows between corporate and ICS networks

- / For example, Data historian is allowed to query information from the control server in the ICS network.
- / If the Data Historian is compromised, attackers may then take control of the control server and thus modify the integrity of the process control




Figure 5-1. Firewall between Corporate Network and Control Network

Network segmentation: Firewall + router

Same story




Figure 5-2. Firewall and Router between Corporate Network and Control Network

Network segmentation: DMZ

There is no direct network flow between corporate and ICS networks




Figure 5-3. Firewall with DMZ between Corporate Network and Control Network

/ Corporate -> DMZ : ALLOW

/ ICS -> DMZ : ALLOW

/ ANY -> ANY : DENY

/ However, beware of client-side vulnerabilities

Network segmentation: DMZ with 2 firewalls

Quite the same as the previous one




Figure 5-4. Paired Firewalls between Corporate Network and Control Network

/ Using 2 firewalls from different brands might prevent some attacks.

/ Also, easier to manage if you have one firewall team for corporate and one for ICS

Network segmentation: DPI and IPS


In order to provide a more context-specific filtering, it is possible to use DPI (Deep Packet Analysis) technology to allow or deny packets based on some protocol fields

- / Example: only authorize Modbus read requests, or deny Modbus 0x5a (90) function
- / These features are available on most firewalls, but most of the time only « industrial » firewall will include the ability to inspect ICS specific protocols.

You can also perform those operations with an IPS, but at the moment there are only a few ICS signatures



Network segmentation: One-way gateways



- / Not mentioned clearly in NIST SP800-82
- / Offers the highest security level, but is also the most difficult to implement
- / A data-diode is a network device based on a real diode, that transmits data only one-way
- / The fact that data cannot be transmitted in the other way is guaranteed by the laws of physics: hack that !
- / Problem: since packets can only go one way, it is not possible to TCP protocol, as even the initial handshake (SYN/SYN-ACK/ACK) would fail. Only UDP-based protocols can be used.
- / Consequence: you have to adapt the infrastructure to use a compliant protocol. That usually means that we need a gateway on each side of the diode

Check my project DYODE : *Do Your Own Diode*
<https://github.com/arnaudsoullie/dyode>

Network segmentation: One-way gateways




Figure 5-2. Firewall and Router between Corporate Network and Control Network

Network segmentation: One-way gateways without diodes

FPGAs

- / FPGA are Integrated Circuits that can be programmed. Once programmed, they are « burned » which means they cannot be reprogrammed.
- / Some gateways use this technology to perform network filtering.
- / It is « less » secure than a data diode since it is not physics-based and errors in FPGA code could allow data to go the other way around. However, it is probably an acceptable risk.

Software data-diode

- / PolyXene is a highly secure multi-security level operating system
- / It is based on several instances of Xen segregated by a micro-kernel
- / It is software-based but with a high security level.
- / Advantages of these solutions is that it can integrate all other security controls (protocol specific controls like read-only, etc..)

Network segmentation: Air gaps



- / Airgap is the notion of having no network connection between two networks. While this notion is important, it lacks the reality check that some form of data exchange is always necessary.
- / For example : update the servers, update the AV signatures, ...

That is why it is necessary to also include laptops and USB drives into the picture, as they are often used to « brake » the airgap

Network segmentation: Laptops

- / From what I've seen, most of the time people consider that there is an airgap if machines are not SIMULTANEOUSLY connected to the corporate network and the ICS networks
- / That is a narrow view, as malware and pentesters can perform actions asynchronously

Example

- / Compromise of the corporate Active Directory
- / Installation of a RAT on the PC from an operational
- / Then program it to perform network reconnaissance on the ICS when it is connected
- / Send back the result to the C&C when the laptop is connected back to the corporate network

Network segmentation: USB drives

When network segmentation is performed correctly, people tend to use USB keys to exchange data between corporate and ICS networks.

The use of USB blocking « caps » is not really a solution, as:

- / You do not really need the key to unlock it, I've seen a lot of people able to do it with a simple screwdriver
- / You usually have to let at least 1 or 2 USB ports available for mouse and keyboard, so what is the point?



What we need is a solution and process to exchange data between corporate and ICS

Importing data from corporate to ICS

Network-based

- / Plug a USB key or drop a file on a share on the corporate network and it will be analyzed and then available on a network share on the ICS network

USB key based

- / Most solutions are based on AV: You plug the key, it is scanned, you unplug the key and go to the ICS. This can be flawed on several layers:
 - › If this workstation is connected, it can be comprised
 - › If you use the same AV as on the computer from which you took the files, what's the point?
 - › If you use the same USB key for corporate and ICS network you could be vulnerable to BadUSB (reprogramming the USB firmware)

Importing data from corporate to ICS

What should be the requirements?

- / Use different USB keys for corporate and ICS
You could have a color code, and use AV / GPOs to filter the USB key authorized by manufacturer / serial number
- / Be able to use several AV
- / If something is detected an alert should be raised and treated

Wait a minute...what about how the file were retrieved in the first place?

- / If you use a standard corporate laptop to connect to the ICS vendor, download the patch and then use your super-secure USB-checking solution, you are still vulnerable...
- / A dedicated PC, not managed by the Active Directory, should be used to download updates. It should have a dedicated proxy configuration that only allows it to connect to a whitelist of websites. Binaries signatures should be checked when provided.

Security monitoring

SCADA and DCS are ALL about monitoring; however, this doesn't include security monitoring...

I strongly believe that security events should be treated as process events

- / Example: an virus detection of one of the workstation should raise an alert not only locally, but also in the control room

Moreover, we have to use the fact that ICS networks do not change that much over time, and consequently we can build a standard basis and act on any modification to it

Network flows and application whitelisting should be achievable on an ICS network



Do you have any
question?

That's all Folks!

Thanks for attending

GitHub repository page for **arnaudsoullie / ics-default-passwords**. The page shows the repository details, including 3 commits, 1 branch, 0 releases, and 1 contributor. A large purple banner with the text "please contribute!" is overlaid diagonally across the page.

The repository contains the following files:

- README.md
- ics-default-passwords.csv

The README.md file content is as follows:

ics-default-passwords

List of default passwords for Industrial Control Systems

The following table is generated from the **ics-default-passwords.csv** file.

Please contribute by sending pull requests if you know any additional default password. If you're not familiar with pull requests or Github, just drop me an email at soullie.arnaud@gmail.com

Default passwords used in ICS products

Manufacturer	Model	Interface	Login	Password	Source	Comm
Schneider	M340	FTP	sysdiag	factorycast@schneider		
Schneider	M340	Web	USER	USER		
Schneider	Premium	FTP	sysdiag	factorycast@schneider		
Schneider	Premium	WEB	USER	USER		
Siemens	S7-1200	Web	admin			

<https://github.com/arnaudsoullie/ics-default-passwords>



Arnaud SOULLIE
Manager

M +33 (0)7 62 86 83 71
Arnaud.soullie@wavestone.com

Alexandrine TORRENTS
Consultant

M +33 (0)7 63 26 79 87
Alexandrine.torrents@wavestone.com

wavestone.com
@wavestone_

PARIS

LONDON

NEW YORK

HONG KONG

SINGAPORE *

DUBAI *

SAO PAULO *

LUXEMBOURG

MADRID *

MILANO *

BRUSSELS

GENEVA

CASABLANCA

ISTANBUL *

LYON

MARSEILLE

NANTES

* Partnerships

WAVESTONE

